

**ADDENDUM NO. 1**

**POTTER CREEK INTERCEPTOR SEWER PROJECT  
Tiffin, Iowa**

**Bids Due and Opened: 10:00 AM, March 2, 2023**

ATTN: Tiffin City Clerk  
Tiffin City Hall  
300 Railroad Street, PO Box 259  
Tiffin, IA 52340  
Phone # (319) 545-2572

The Plans and Specifications prepared for this project are hereby modified, amended or clarified as follows:

**A. CONTRACT DOCUMENTS:**

1. Specification 04910 Pipe Bursting, 2.01.A.2 Minimum wall thickness: DR 17 shall refer to DIPS HDPE pipe with an average inside diameter of approximately 9.7-inches.


**B. PLANS.**

1. Plan sheets D.05-D.08; All instances of DR 17 HDPE shall refer to DIPS HDPE pipe with an average inside diameter of approximately 9.7-inches.

**C. VALIDITY OF BID:**

**PLEASE NOTE:**

In order for the Bid to be valid, the receipt of Addendum No. 1 must be acknowledged in the appropriate space on the FORM OF PROPOSAL. If no space is provided, note receipt of this addendum above the table of bid items.

  
\_\_\_\_\_  
Benjamin A. Carhoff, P.E.  
Iowa Registration No. 19939  
My license renewal date is December 31, 2023

27 February, 2023  
Date